

Annotations

- 1. The picture shows that the adjusting axle is on the H point;
- 2. The thermostat's capillary tube and the temperature sensing bulb are easy to damage, They couldn'd be damaged\pressed to flat/broke off, or it will influence the thermostat's function and temperature;
- 3. Thermastat's working temperature is 25°C, the capillary tub must be immersed in heat water of 30 \sim 80mm deep, or the testing result will not be correct;
- 4. Testing condition:the model of temperature variety is $\leq 1^{\circ}$ C/lmin.

- 1.H point temperature/DFF:60±3°C DIFF: 4±2°C
- 2.The fixing electric voltageAC250V
 The fixing electric current16A
- 3.Electrical strength: 2000VAC/1min/0.5mA
- 4. The touching electric resistance <50m Ω
- 5. Insulating electric resistance >100 M Ω
- 6.The highest temperature the main body can endured:125°C
- 7.The hignest temperature the temperature feeling tube can endured:90° C
- 8.Product's life:>10 times

